



St Louis Park Energy Savings Summary YTD Report September 2006- August 2007



| Building | % Electric | % Demand | % Natural Gas/Oil | % Total Energy Mmbtu | \$ Cost Avoided |
|------------------------------|-------------|-------------|-------------------|----------------------|------------------|
| Aquila Primary | 1% | 4% | 4% | 3% | (\$2,624) |
| Cedar Manor Intermediate | -18% | -9% | -1% | -7% | \$6,217 |
| Lenox Community Center | -19% | -10% | -15% | -16% | \$12,287 |
| PSI/Central Community Center | -19% | -10% | -11% | -13% | \$28,180 |
| Peter Hobart Primary | -15% | -1% | -7% | -10% | \$6,964 |
| St Louis Park Jr High | -26% | -12% | -20% | -21% | \$43,491 |
| St Louis Park Sr High | -19% | -16% | -6% | -11% | \$47,784 |
| Susan Lindgren Intermediate | -15% | -8% | 12% | 2% | \$1,586 |
| Building & Grounds | -28% | 0% | -18% | -19% | \$6,914 |
| District Summary | -18% | -11% | -10% | -12% | \$150,799 |

The report shows the % of energy savings compared to baseline data for each individual building and district-wide. MMBtu (Million British Thermal Units) is a converted measurement of total energy use as it relates to electricity and natural gas. A negative percentage means you saved energy and a positive percentage means you used more energy this year than in the baseline. \$ Avoided is an estimated calculation based on current utility rates and energy savings for electric and natural gas. The goal of the Schools for Energy Efficiency program is to achieve an annual 10% reduction in energy use district-wide.

Questions or Comments? Please contact Anne Anderson, District Energy Coordinator @ (612) 269-8063